

TEST OBJECT

HYBRID AIR HUMIDIFIER SYSTEM CONDAIR DL

DEVELOPER AND MANUFACTURER

CONDAIR AG, PFÄFFIKON, SWITZERLAND

TEST CONDITIONS

The hybrid air humidifier system Condair DL was installed and commissioned in an air handling unit at the technical center of the SGS Institute Fresenius GmbH, Taunusstein. There it was operated under real-life conditions for six months (June to November 2013) and observed throughout. As part of the investigation, microbiological contamination was applied in a targeted way in order to test the function of the DL unit under worst case conditions.

TEST REQUIREMENTS

Humidifier water: The industry standard recommendation in VDI 6022 is < 1000 CFU/ml. For the Condair DL system Condair defined a **max. value of 150 CFU/ml**.

TEST RESULT

- The results of the investigations were below the defined test requirements.
- The tested hybrid air humidifier system Condair DL, fulfil all defined Standards.

WE ARE THEREFORE ABLE TO ISSUE THE SGS INSTITUT FRESENIUS HYGIENE CERTIFICATE AND TO CONFIRM THAT THE HYBRID AIR HUMIDIFIER SYSTEM CONDAIR DL TESTED WORKS HYGIENICALLY.

The issue of the test certificate is linked to the following operating conditions:

- Operation of the system's own silver ionization
- Operation with upstream reverse osmosis plant
- Microbiological water quality in accordance with VDI 6022 total colony count of max. 100 CFU/ml)
- Adherence to prescribed operating standards and maintenance intervals

RADOLFZELL, 21.04.2015



p.p. Hans-Georg W. Karbach
Branch Manager
Operational Field Services Manager
Environment, Health and Safety



p.p. Peter Breig
Groupleader Field Service and Logistic
Environment, Health and Safety

Certifying Body:
SGS INSTITUT FRESENIUS GmbH
Güttinger Straße 37
D-78315 Radolfzell
www.sgsgroup.de

This document is issued by the Company subject to its General Conditions of Service (www.sgsgroup.de/agn). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. This document is an original. If the document is submitted digitally, it is to be treated as an original within the meaning of UCP 600. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS INSTITUT FRESENIUS IS PART OF SGS, THE WORLD'S LEADING INSPECTION, VERIFICATION, TESTING AND CERTIFICATION COMPANY.

